

Date: 10 October 2017

Ref: Replacement glazing

Dear Member,

Replacement of glazing materials following wind damage caused by the adverse weather conditions.

Part A of the National Building Regulations, issued in terms of the National Building Regulations and Building Standards Act 1977 requires in Regulation A1 (8) (a) that alterations **shall** comply with the requirements of the Act.

Country Representative





Hence replacement glazing shall be executed strictly in accordance with SANS 10400-N: 2012 Edition 3 which states, inter alia, that safety glazing materials **shall** comply with SANS 1263-1 shall be used where:

## Quote

"All glazing for occupancy or building classification is A3 (places of instruction), E1 (place of detention), E2 (hospital), E3 (other institutional (residential buildings) and H2 (dormitory), where such is associated with a building of occupancy classification A3, E1, E2 or E3 **shall** be safety glazing material that complies with the requirements of SANS 1263-1" Unquote

Kind Regards

For AAAMSA

HÁNS Á SCHEFFERLIE TECHNICAL ADVISOR



Reg. No. 1974/000006/08 Association NPC VAT No. 4900141153

Tel (011) 805-5002 Fax (011) 805-5033

Incorporating:







Expanded Polystyrene













